6SY07

TEST REPORT			
Prepared For :	Technology Co., Ltd.		
Address :	Shenzhen 518106, China		
manufacturer :	Technology Co., Ltd.		
Address :	Shenzhen 518106, China		
Product Name:	Surgical Face Mask(3 layers)		
Model :	C-001		
Prepared By :	TXB RHEINLAND TXB Rhienland Testing Services Crop Libited		
	SAT NOTAS		

Test Date :2020-02-28

Date of Report: 2020-03-06

Report No. : TXB202 6SY07

Test Requested: Selected test (s) in the selected parts as requested by client

Test Method: Please refer to next page(s). Test Result: Please refer to next page(s).

This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of TXB this test

report shall not be copied except in full and published as advertisement.TXB Physical & Chemical Lab.

Report No:TXB202 6SY07

	EN14683:2005			
Clause	Requirement + Test	Result - Remark	Verdict	
1.	Basic requirements for masks			
	1.1 The mask should cover the snout of the wearer	Untreated sample:		
	1.2. There should be good facial adhesion	1#-3# pass		
	1.3. There must be no holes or stains on the surface.			
	Nose clip			
	2.1 Masks should be equipped with nose clips	Untreated sample: 1#-3# pass		
	2.2 The nose clip should be adjustable			
3.	Mask band			
	3.1 should be easily adjusted with 10N or more	Untreated sample: 1# 2# 3# 4# 18.2N 19.3N 18.8N 19.7N		
4	Resistance to airflow			
	4.1 343.2Pa or less, temperature: 23 Relative humidity: 34.6%	Untreated sample: 1# 2# 3# 97.4 96.8 97.8	P	
5	Synthetic blood penetration			
	5.1 There should be no infiltration on the inside of the mask	1#-5# No penetration in the mask		
6	Surface moisture resistance			
	6.1 Moisture resistance is greater than or equal to 3			
7	Flame retardant performance, afterflame time			
	7.1 5S or less	1s	р	
8	Microorganism			
	8.1 The initial contaminated bacteria should be 100 cfu /g or less	80 cfu /g	р	
	8.2 No detectable E. coli, pathogenic pyogenic bacteria, fungi	No		
9	9.1Bacterial filtration efficiency(BFE) should be 95 % or More	99.48	р	
	9.2Differential Pressure Less than 40 pa / cm2	29.6		
	9.3Microbial cleanliness should be 30 cfu /g or less 25			
	9.4splash resistance pressure			



